



SPACING  
 POWER = 12" min  
 CONTROL = 12" min  
 SIGNAL = 18" min



- NOTES:  
 1. SPACING BETWEEN SUPPORTS NOT TO EXCEED 10'  
 2. HORIZONTAL SEPARATION SHOWN BETWEEN TRAYS IS FOR TRAYS OF LIKE SERVICE.
- | ITEM NO. | DESCRIPTION   |
|----------|---|
| 1        | GALVANIZED STEEL SINGLE CHANNEL, B-LINE B22                                       |
| 2        | BRACKET, B-LINE B188  |
| 3        | BRACKET, B-LINE B189  |
| 4        | BRACKET, B-LINE B292  |
| 5        | 1/2" SPRING NUT, B-LINE N225  |
| 6        | 1/2" X 1" HEX HEAD BOLT B-LINE HHSC   |
| 7        | B-LINE TRAY CLAMP 92N-1208NB C/W 1/4" X 1-1/4" BOLT & 1/4" B-LINE SPRING NUT N224 |
| 8        | 1/2" HEX NUT & LOCK WASHER  |

- | ITEM NO. | DESCRIPTION   |
|----------|---|
| 1        | GALVANIZED STEEL DOUBLE CHANNEL, B-LINE B22A                                      |
| 2        | GALVANIZED STEEL SINGLE CHANNEL, B-LINE B22                                       |
| 3        | BEAM CLAMP, B-LINE B211   |
| 4        | 90° ANGLE, B-LINE B232  |
| 5        | 1/2" SPRING NUTS, B-LINE N225   |
| 6        | 1/2" X 1" HEX HEAD BOLT B-LINE HHSC   |
| 7        | 1/2" HEX NUT & LOCK WASHER  |
| 8        | B-LINE TRAY CLAMP 92N-1208NB C/W 1/4" X 1-1/4" BOLT & 1/4" B-LINE SPRING NUT N224 |
| 9        | 1/2" X 1 1/2" HEX HEAD BOLT C/W LOCK WASHER B-LINE HHSC                           |

- | ITEM NO. | DESCRIPTION   |
|----------|---|
| 1        | GALVANIZED STEEL DOUBLE CHANNEL, B-LINE B22A                                      |
| 2        | GALVANIZED STEEL SINGLE CHANNEL, B-LINE B22                                       |
| 3        | BEAM CLAMP, B-LINE B211   |
| 4        | 90° ANGLE, B-LINE B232  |
| 5        | 1/2" SPRING NUTS, B-LINE N225   |
| 6        | 1/2" X 1" HEX HEAD BOLT B-LINE HHSC   |
| 7        | 1/2" HEX NUT & LOCK WASHER  |
| 8        | B-LINE TRAY CLAMP 92N-1208NB C/W 1/4" X 1-1/4" BOLT & 1/4" B-LINE SPRING NUT N224 |
| 9        | 1/2" X 1 1/2" HEX HEAD BOLT C/W LOCK WASHER B-LINE HHSC                           |
| 10       | BRACE B-LINE B261-12  |

No.	DATE	BY	DESCRIPTION	CHKD.
REVISIONS				

DWG. No.	TITLE
REFERENCE DRAWINGS	
<input type="checkbox"/>	PRELIMINARY - NOT FOR CONSTRUCTION
<input checked="" type="checkbox"/>	APPROVED FOR CONSTRUCTION
<input type="checkbox"/>	SUPERSEDES ALL PREVIOUS ISSUES
BY	DATE
DESIGNED	DRAWN
CHECKED	DATE
DESIGN	DRAWING
PROJECT MANAGER	SPECIFICATION No.
PROJECT TECHNICIAN	

**ENGINEERING LTD.**  
 Fredericton, NB

AREA NAME

**TRAY SUPPORT DETAILS AND GROUNDING/BONDING DETAILS**

JOB No. CONSULTANT DWG. No.

DWG. No. 256084-00032